

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## PROMASEAL® Floor Waste Cast-in Collar

has been tested/approved in accordance with “Australian Standard 1530: Part 4 Methods for fire tests on building materials, components and structures” and “Australian Standard 4072.1 Components for the protection of openings in fire resistant separating elements Part 1: Service penetrations and control joints”

(Refer to reports: A-16-024A, A-17-014, A-17-029A, A-17-047, A-17-031, A-17-003)

### Penetrations in minimum 150mm concrete slab with PROMASEAL® FWC100

Service	Report	FRL
100mm HDPE with S-Trap	A-16-024A	-/240/240
100mm uPVC with S-Trap	A-16-024A	-/240/240
100mm uPVC with 4-way riser	A-16-024A	-/240/240
100mm dBlue stack	A-17-014	-/240/240
100mm Raupiano with 4-way riser	A-17-029A	-/240/240
100mm uPVC with S-Trap	A-17-029A	-/240/240

### Penetrations in minimum 150mm concrete slab with PROMASEAL® FWC100H (High Top)

Service	Report	FRL
100mm Raupiano with 4-way riser	A-17-029A	-/240/240
100mm uPVC with S-Trap	A-17-029A	-/240/240
80mm uPVC with S-Trap <sup>(1)</sup>	A-17-047	-/240/240
50mm FastFlow uPVC with drain pipe <sup>(1)</sup>	A-17-047	-/240/240
50mm uPVC with S-Trap <sup>(1)</sup>	A-17-047	-/240/240

(1) 100mm collar with reducer plate

### Penetrations in minimum 90mm thick concrete slab with PROMASEAL® FWC100

Service	Report	FRL
50mm uPVC with S-Trap	A-17-031	-/120/90
100mm uPVC	A-17-031	-/120/90



\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)

Head Office

New South Wales Office

Victoria Office

Queensland Office

1 Scotland Road, Mile End South, SA 5031 AUSTRALIA

Unit 1, 175 Briens Road, Northmead, NSW 2152 AUSTRALIA

Suite 205, 198 Harbour Esplanade, Docklands, VIC 3008 AUSTRALIA

433 Logan Road, Stones Corner, QLD 4120 AUSTRALIA

an etex company