

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMASEAL® FCS Retrofit Collar Socket

For concrete floors have been tested/approved in accordance with “Australian Standard 1530: Part 4 Methods for fire tests on building materials, components and structures” protecting pipe penetrations in floors and walls

(Refer to reports EWFA 29592300.3, SFC 45756.2, FSRG A-16-012, FSRG A-15-1034, FAR 3758)

Pipe Material	Pipe Size	Element	Fitting in the Collar	Protection	FRL
uPVC	43	Floor Slab	Yes	PROMASEAL® FCS 40	-/240/240
uPVC	56	Floor Slab	Yes	PROMASEAL® FCS 50	-/240/240
uPVC	69	Floor Slab	Yes	PROMASEAL® FCS 65	-/240/240
uPVC	110	Floor Slab	Yes	PROMASEAL® FCS 100	-/240/240
HDPE	50	Floor Slab	Yes	PROMASEAL® FCS 40	-/180/180
HDPE	56	Floor Slab	Yes	PROMASEAL® FCS 50	-/180/180
HDPE	75	Floor Slab	Yes	PROMASEAL® FCS 65	-/180/180
HDPE	110	Floor Slab	Yes	PROMASEAL® FCS 100	-/240/240
ABS	40	Floor Slab	No	PROMASEAL® FCS 40	-/240/240
ABS	50	Floor Slab	No	PROMASEAL® FCS 50	-/240/240
ABS	100	Floor Slab	No	PROMASEAL® FCS 100	-/240/240
BluePower	100	Floor Slab	Yes	PROMASEAL® FCS 100	-/120/120
Drink Pipe	120	Floor Slab	No	PROMASEAL® FCS 100	-/120/120
Drink Pipe	100	Floor Slab	No	PROMASEAL® FCS 100	-/120/120
Drink Pipe	120	Wall (128mm)	No	PROMASEAL® FCS 100	-/90/90 ⁽¹⁾
uPVC	100	Wall (116mm)	Yes	PROMASEAL® FCS 100	-/120/120



⁽¹⁾ Collar on the exposed side only.

Contact Promat for installation instructions on steel decking (FAR 3758)

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au