

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMAT Fire Collars

As described below

For 128mm lightweight partitions and 150mm slab penetrations

have been tested/approved in accordance with

“Australian Standard 1530: Part 4

Methods for fire tests on building materials, components and structures”

protecting Rehau RAUPIANO PLUS® pipe penetrations

for a range of pipe sizes described below. (Test/Approval No. 26149-05, A-16-066, A-17-029A)

Pipe Diameter	Construction	Collar	FRL
40	Floor / Slab	PROMASEAL® Green 40	-/240/180
	Floor / Slab	PROMASTOP® UniCollar	-/240/120
	Plasterboard Wall	PROMASTOP® UniCollar	-/240/180
50	Floor / Slab	PROMASEAL® Green 50	-/240/180
	Floor / Slab	PROMASEAL® Hi-Blu 65	-/240/180
	Floor / Slab	PROMASTOP® UniCollar	-/120/120
	Plasterboard Wall	PROMASTOP® UniCollar	-/240/120
75	Floor / Slab	PROMASEAL® Green 80	-/240/240 ⁽¹⁾
	Floor / Slab	PROMASTOP® UniCollar	-/120/120
	Plasterboard Wall	PROMASTOP® UniCollar	-/240/120
90	Floor / Slab	PROMASEAL® Green 100	-/180/180
	Floor / Slab	PROMASTOP® UniCollar	-/120/120
	Plasterboard Wall	PROMASTOP® UniCollar	-/120/120
110	Floor / Slab	PROMASEAL® Green 100	-/180/180
	Floor / Slab	PROMASEAL® Hi-Blu 100	-/180/120
	Floor / Slab	PROMASTOP® UniCollar	-/180/120
	Plasterboard Wall	PROMASTOP® UniCollar	-/240/120
110 (Floor Waste)	Floor / Slab	PROMASEAL® FWC100	-/240/240 ⁽²⁾
	Floor / Slab	PROMASEAL® FWC100H	-/240/240 ⁽²⁾
	Floor / Slab	PROMASEAL® FWR	-/240/240 ⁽³⁾
160	Floor / Slab	PROMASEAL® FC 150	-/240/180
	Plasterboard Wall	PROMASEAL® FC 150	-/240/180
200	Floor / Slab	PROMASEAL® FC 250	-/240/120
	Plasterboard Wall	PROMASEAL® FC 250	-/240/180

⁽¹⁾ PROMASEAL Graf 4T installed in the collar, ⁽²⁾ Floor waste with 4-way riser, ⁽³⁾ Floor waste with S-trap

For results in thinner slabs, contact Promat

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au