

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMASEAL® AG Intumescent Sealant

For lightweight and AAC partitions has been tested/approved in accordance with “Australian Standard 1530: Part 4: 2014 Methods for fire tests on building materials, components and structures” protecting various service penetrations

(Reports: FSRG A-17-034, FSRG A-17-042B, FSRG A-17-074)

Service	Hole Size (mm)	Depth of Sealant (mm)	Wall Type	FRL	Approval no.
20mm PEX pipe	70	13	90mm Plasterboard Partition	-/60/60	A-17-034
Polyethylene Lagged Pair Coil	70	13	90mm Plasterboard Partition	-/60/60	A-17-034
16mm PEX pipe	70	13	116mm Plasterboard Partition	-/120/120	A-17-074
20mm PEX pipe	70	13	116mm Plasterboard Partition	-/120/120	A-17-074
25mm PEX pipe	70	13	116mm Plasterboard Partition	-/120/90	A-17-074
20mm PEX pipe	70	13	75mm AAC Panels	-/120/120	A-17-042B
FR Armaflex Lagged Pair Coil & Three Phase Cable	70	13	75mm AAC Panels	-/120/90	A-17-042B
FR Armaflex Lagged Pair Coil & Three Phase Cable	70	13	75mm AAC Panels with 13mm FR Plasterboard Local Thickening	-/120/120	A-17-042B
Polyethylene Lagged Pair Coil & Three Phase Cable	70	13	75mm AAC Panels with 13mm FR Plasterboard Local Thickening	-/120/60	A-17-042B



* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au

Head Office

New South Wales Office

Victoria Office

Queensland Office

1 Scotland Road, Mile End South, SA 5031 AUSTRALIA

Unit 1, 175 Briens Road, Northmead, NSW 2152 AUSTRALIA

Suite 205, 198 Harbour Esplanade, Docklands, VIC 3008 AUSTRALIA

433 Logan Road, Stones Corner, QLD 4120 AUSTRALIA

an **etex** company