

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## PROMAT Fire Collars and Sealant

have been tested/approved in accordance with “Australian Standard 1530: Part 4  
Methods for fire tests on building materials, components and structures”  
protecting pipe penetrations through 51mm, 64mm & 78mm Speedpanel

(Refer to reports: 25518-04, A-12-775a, A-12-777, 25472-04, 29592300.3, A-14-906, A-15-1002, A-16-077, A-16-054, A-16-071, A-15-989)

Penetration	Protection	Local Thickening <sup>(1)</sup>	Wall	FRL
40mm uPVC	PROMASEAL® FC 40	None	78mm Speedpanel	-/120/120
40mm uPVC	PROMASEAL® FC 40	Yes		-/120/120
50mm uPVC	PROMASEAL® FC 50	Yes		-/120/120
65mm uPVC	PROMASEAL® FC 65	Yes		-/120/120
80mm uPVC	PROMASEAL® FC 80	Yes		-/120/120
100mm uPVC	PROMASEAL® FC 100	None		-/180/60
100mm uPVC	PROMASEAL® FC 100	Yes		-/120/120
150mm uPVC	PROMASEAL® FC 150	None		-/120/60
150mm uPVC	PROMASEAL® FC 150	Yes		-/120/120

Penetration	Protection <sup>(2)</sup>	Local Thickening	Wall & FRL
40mm uPVC	PROMASEAL® FCW 40	None	FRL -/60/60 in 51mm Speedpanel FRL -/90/90 in 64mm Speedpanel FRL -/120/120 in 78mm Speedpanel
50mm uPVC	PROMASEAL® FCW 50	None	
65mm uPVC	PROMASEAL® FCW 65	None	
80mm uPVC	PROMASEAL® FCW 80	None	
100mm uPVC	PROMASEAL® FCW 100	None	

<sup>(1)</sup> 25mm PROMATECT® 100 each side of the wall around the penetration, extending a minimum of 100mm from extents of the collar. Can also be used to cover oversized hole.

<sup>(2)</sup> Cone of PROMASEAL® A Acrylic Sealant to be applied where the PROMASEAL® FCW extends out of the wall.

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## PROMAT Fire Collars and Sealant

have been tested/approved in accordance with “Australian Standard 1530: Part 4  
Methods for fire tests on building materials, components and structures”  
protecting pipe penetrations through 78mm Speedpanel

(Refer to reports: 25518-04, A-12-775a, A-12-777, 25472-04, 29592300.3, A-14-906, A-15-1002, A-16-077, A-16-054, A-16-071, A-15-989)

Penetration	Protection	Local Thickening*	Wall	FRL
40mm HDPE	PROMASEAL® FC 40	Yes	78mm Speedpanel	-/120/120
56mm HDPE	PROMASEAL® FC 50	Yes		-/120/120
56mm HDPE	PROMASEAL® FC 65	Yes		-/120/120
75mm HDPE	PROMASEAL® FC 80	Yes		-/120/120
110mm HDPE	PROMASEAL® FC 100	Yes		-/120/120
125mm HDPE	PROMASEAL® FC 150	Yes		-/120/120
160mm HDPE	PROMASEAL® FC 150	Yes		-/120/120
200mm HDPE	PROMASEAL® FC 250	Yes		-/120/120
250mm HDPE	PROMASEAL® FC 250	Yes		-/120/120
315mm HDPE	PROMASEAL® FC 300	Yes <sup>(1)</sup>		-/120/120

\*25mm PROMATECT® 100 each side of the wall around the penetration, extending a minimum of 100mm from extents of the collar. Can also be used to cover oversized hole.

<sup>(1)</sup> One side of the Speedpanel thickened with 64mm steel stud and clad with 2 x 16mm FR plasterboard

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## PROMAT Fire Collars and Sealant

have been tested/approved in accordance with “Australian Standard 1530: Part 4  
Methods for fire tests on building materials, components and structures”

protecting pipe penetrations through 78mm Speedpanel

(Refer to reports: 25518-04, A-12-775a, A-12-777, 25472-04, 29592300.3, A-14-906, A-15-1002, A-16-077, A-16-054, A-16-071, A-15-989)

Penetration	Protection	Pipe Insulation	Wall	FRL
32mm copper	PROMASEAL® A Acrylic Sealant	None	78mm Speedpanel	-/120/-
100mm copper	PROMASEAL® A Acrylic Sealant	None		-/120/-
100mm copper or ferrous	PROMASEAL® SupaMastic	None		-/120/-
150mm copper or ferrous	PROMASEAL® SupaMastic	None		-/120/-
200mm copper	PROMASEAL® A Acrylic Sealant	None		-/120/-
32mm copper or ferrous	PROMASEAL® SupaMastic	38mm Fibretex 450 Rockwool, 600mm each side of the wall Or 50mm Fibretex 820 Rockwool, 600mm each side of the wall and through the aperture, with PROMASEAL® IBS		-/120/120
100mm copper or ferrous	PROMASEAL® SupaMastic			-/120/120
150mm copper or ferrous	PROMASEAL® SupaMastic			-/120/120
320mm ferrous	PROMASEAL® SupaMastic	50mm Fibretex 820 Rockwool, 600mm each side of the wall with PROMASEAL® IBS		-/120/120
19mm copper	PROMASEAL® FlexiWrap	25mm thick FR Armaflex		-/120/120
100mm copper	PROMASEAL® A Acrylic Sealant	600mm long PROMASEAL® SupaWrap each side of wall	-/120/120	

\*25mm PROMATECT® 100 each side of the wall around the penetration, extending a minimum of 100mm from extents of the collar

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## PROMAT Fire Collars and Sealant

have been tested/approved in accordance with “Australian Standard 1530: Part 4  
Methods for fire tests on building materials, components and structures”  
protecting pipe penetrations through 78mm Speedpanel

(Refer to reports: 25518-04, A-12-775a, A-12-777, 25472-04, 29592300.3, A-14-906, A-15-1002, A-16-077, A-16-054, A-16-071, A-15-989)

Penetration	Protection	Local Thickening	Wall	FRL
Single 6mm data cable	PROMASEAL® Pillows & PROMASEAL® A Acrylic Sealant	20mm PROMATECT® 100 each side of the wall <sup>(1)</sup>	78mm Speedpanel	-/120/120
11mm bunch of sheathed telecommunication cables	PROMASEAL® Pillows & PROMASEAL® A Acrylic Sealant			-/120/120
20mm bunch of sheathed telecommunication cables	PROMASEAL® Pillows & PROMASEAL® A Acrylic Sealant			-/120/120
4 x 32mm single core electrical cables	PROMASEAL® Pillows & PROMASEAL® A Acrylic Sealant			-/120/30
50 x CAT7 data cables	PROMASEAL® Pillows & PROMASEAL® A Acrylic Sealant			-/120/120
5 x 2.5mm twin & earth electrical cables	PROMASEAL IBS & PROMASEAL® A Acrylic Sealant	None	78mm Speedpanel	-/120/120
1 x 2.5mm twin & earth electrical cables	PROMASEAL® A Acrylic Sealant			-/120/120
1 x TPS electrical cables	PROMASEAL® A Acrylic Sealant			-/120/120
2 x TPS electrical cables	PROMASEAL® A Acrylic Sealant			-/120/120

<sup>(1)</sup> The PROMATECT 100 thickening around the penetration shall extend 100mm beyond the penetration and be fixed with 50mm long batten screws at 200mm centers

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## PROMAT Fire Collars and Sealant

have been tested/approved in accordance with “Australian Standard 1530: Part 4  
Methods for fire tests on building materials, components and structures”  
protecting pipe penetrations through 51mm & 78mm Speedpanel

(Refer to reports: 25518-04, A-12-775a, A-12-777, 25472-04, 29592300.3, A-14-906, A-15-1002, A-16-077, A-16-054, A-16-071, A-15-989)

Penetration	Protection	Local Thickening*	Wall	FRL
16mm PEX/AL/PEX	PROMASEAL® CFC 32	Yes	78mm Speedpanel	-/240/180
20mm PEX/AL/PEX	PROMASEAL® CFC 32	Yes		-/240/240
16mm PEX	PROMASEAL® CFC 32	Yes		-/120/120
20mm PEX	PROMASEAL® CFC 32	Yes		-/120/120
25mm PEX	PROMASEAL® CFC 32	Yes		-/120/120

Penetration	Protection	Local Thickening*	Wall	FRL
25mm PEX	PROMASEAL® CFC 32 central within the wall	None	51mm Speedpanel	-/60/60

\*25mm PROMATECT® 100 each side of the wall around the penetration, extending a minimum of 100mm from extents of the collar

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)