

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## PROMASEAL® CFC32 Conduit Collars

on pipe penetrations through walls

have been tested/approved in accordance with

“Australian Standard 1530: Part 4

Methods for fire tests on building materials, components and structures”

PROMASEAL® CFC32 Conduit Collars on each face of a 128mm thick FR plasterboard wall

| Penetrating Element                                | FRL       | Report   |
|--|-----------|----------|
| 16mm PEX pipe                                      | -/180/180 | 2253502  |
| 20mm PEX pipe                                      | -/180/180 | 2253502  |
| 25mm PEX pipe                                      | -/180/180 | 41281.1  |
| 32mm PEX pipe                                      | -/180/120 | A-13-852 |
| 16mm PEX/AL/PEX pipe                               | -/180/180 | 2257300  |
| 20mm PEX/AL/PEX pipe                               | -/180/180 | 41281.1  |
| 25mm PEX/AL/PEX pipe                               | -/180/30  | 2257300  |
| 32mm PEX/AL/PEX pipe                               | -/180/90  | 2253502  |
| 25mm uPVC pipe                                     | -/180/180 | A-13-852 |
| 32mm uPVC pipe <sup>(1)</sup>                      | -/180/90  | FSP 0643 |
| 32mm uPVC pipe with Polypropylene electrical cable | -/120/120 | A-12-752 |
| 18mm PB pipe                                       | -/180/180 | 41281.1  |
| 22mm PB pipe                                       | -/180/180 | 41281.1  |
| 25mm cPVC pipe                                     | -/120/120 | A-15-978 |
| 29mm coaxial cable                                 | -/180/120 | A-12-762 |
| 6 x CAT7 cables                                    | -/180/120 | A-12-762 |
| 25mm uPVC pipe with 4 x electrical cables          | -/120/120 | FCO 1886 |
| 32mm uPVC pipe with 4 x electrical cables          | -/120/120 | FCO 1886 |



<sup>(1)</sup> Collar on exposed face only

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)

Head Office

New South Wales Office

Victoria Office

Queensland Office

1 Scotland Road, Mile End South, SA 5031 AUSTRALIA

Unit 1, 175 Briens Road, Northmead, NSW 2152 AUSTRALIA

Suite 205, 198 Harbour Esplanade, Docklands, VIC 3008 AUSTRALIA

1/68 Lisgar Street, Virginia, QLD 4014 AUSTRALIA

an etex company